



PUBLIC WORKS DEPARTMENT

2095 MAIN STREET / P.O. BOX 936

FERNDALE, WA 98248

(360) 384-4006

TRANSMITTAL SHEET

Data sent: June 2, 2025
Sent to: All Planholders
Deliver to: Project Estimator
Transmission sent from: Public Works Department, City of Ferndale
Number of pages including this page: 3

CONFIRMATION OF RECEIPT OF ADDENDUM

PROJECT: Thornton to Newkirk Watermain Improvements
City Project No. WA2010-01

Please complete the following form and email back to the Public Works Department, City of Ferndale at public-works@cityofferndale.org as soon as possible.

Have you received Addendum No. 2 for the above-mentioned project?

☐ **YES, we received Addendum No. 2**

Signature: _____ **Date:** _____

Company Name: _____

TRANSMITTAL SHEET

TO:	FROM:
ALL BIDDERS	Luis Ponce, P.E.
COMPANY:	DATE:
	June 2, 2025
ADDRESS:	TOTAL NO. OF PAGES INCLUDING COVER:
	2
RE:	
City of Ferndale	
Addendum 2	
Thornton To Newkirk Watermain Improvements Project	
City Project No. WA2010-01	

NOTES/COMMENTS:


To the attention of all bidders for the above project:

Please find the enclosed Addendum for the above referenced project.

The enclosed ADDENDUM is to be considered as much a part of the Contract Documents as if it were included in the body of the plans and specifications, and will be incorporated in and made a part of the contract when awarded and when formally executed.

The Bidder shall acknowledge in writing, on the bid form, this addendum in order to have the bid considered.

Luis Ponce, P.E.



ADDENDUM NO. 2
To the Contract Documents for:
City of Ferndale, Washington
Thornton To Newkirk Watermain Improvements Project

City of Ferndale Project No. WA2010-01

Item 1
SPECIFICATIONS


1-08.5 Time for Completion

Item 2 of Addendum No. 1 incorrectly read "Contractor Agency". Item 2 of Addendum No. 1 is deleted and replaced with the following:

Contract time shall begin on the mutually agreed upon start date between the Contracting Agency and the Contractor stated in the written Notice To Proceed provided to the Contractor. In no case shall the beginning of contract time be later than *****September 1, 2025*****.

END OF ADDENDUM NO. 2

Acknowledgement that this addendum has been received is required on the Bid Proposal.



Luis Ponce, P.E.