



PUBLIC WORKS DEPARTMENT

2095 MAIN STREET / P.O. Box 936

FERNDALE, WA 98248

(360) 384-4006

TRANSMITTAL SHEET

Data sent: June 5, 2025

Sent to: All Planholders

Deliver to: Project Estimator

Transmission sent from: Public Works Department, City of Ferndale

Number of pages including this page: 3

CONFIRMATION OF RECEIPT OF ADDENDUM

PROJECT: Thornton to Newkirk Watermain Improvements
City Project No. WA2010-01

Please complete the following form and email back to the Public Works Department, City of Ferndale at public-works@cityofferndale.org as soon as possible.

Have you received Addendum No. 4 for the above-mentioned project?

YES, we received Addendum No. 4

Signature: _____ **Date:** _____

Company Name: _____



TRANSMITTAL SHEET

TO:	FROM:
ALL BIDDERS	Luis Ponce, P.E.
COMPANY:	DATE:
	June 5, 2025
ADDRESS:	TOTAL NO. OF PAGES INCLUDING COVER:
	2
RE:	
City of Ferndale	
Addendum 4	
Thornton To Newkirk Watermain Improvements Project	
City Project No. WA2010-01	

NOTES/COMMENTS:

To the attention of all bidders for the above project:

Please find the enclosed Addendum for the above referenced project.

The enclosed ADDENDUM is to be considered as much a part of the Contract Documents as if it were included in the body of the plans and specifications, and will be incorporated in and made a part of the contract when awarded and when formally executed.

The Bidder shall acknowledge in writing, on the bid form, this addendum in order to have the bid considered.

Luis Ponce, P.E.



ADDENDUM NO. 4
To the Contract Documents for:
City of Ferndale, Washington
Thornton To Newkirk Watermain Improvements Project

City of Ferndale Project No. WA2010-01

Item 1

HDPE sizing and pressure requirements shall be as follows:

HDPE PIPE FOR WATERMAIN 14 IN. DIAM. shall be DR 9 and shall have an Outside Diamer per Table 4 of ANSI/AWWA C906, which has an average of 15.30 In. Outside Diameter and an average of 11.696 In. Inside Diameter.

HDPE PIPE FOR CASING 20 IN. DIAM. shall be DR 11 and shall have an Outside Diamer per Table 4 of ANSI/AWWA C906, which has an average of 21.60 In. Outside Diameter and an average of 17.436 In. Inside Diameter.

All references to the previous HDPE sizing and pressure ratings shall be replaced with the revised HDPE sizing and pressure ratings.

END OF ADDENDUM NO. 4

Acknowledgement that this addendum has been received is required on the Bid Proposal.



Luis Ponce, P.E.