



PUBLIC WORKS DEPARTMENT

2095 MAIN STREET / P.O. Box 936

FERNDALE, WA 98248

(360) 384-4006

TRANSMITTAL SHEET

Data sent: June 9, 2025

Sent to: All Planholders

Deliver to: Project Estimator

Transmission sent from: Public Works Department, City of Ferndale

Number of pages including this page: 3

CONFIRMATION OF RECEIPT OF ADDENDUM

PROJECT: Thornton to Newkirk Watermain Improvements
City Project No. WA2010-01

Please complete the following form and email back to the Public Works Department, City of Ferndale at public-works@cityofferndale.org as soon as possible.

Have you received Addendum No. 5 for the above-mentioned project?

YES, we received Addendum No. 5

Signature: _____ **Date:** _____

Company Name: _____

TRANSMITTAL SHEET

TO:	FROM:
ALL BIDDERS	Luis Ponce, P.E.
COMPANY:	DATE:
	June 9, 2025
ADDRESS:	TOTAL NO. OF PAGES INCLUDING COVER:
	2

RE:
City of Ferndale
Addendum 5
Thornton To Newkirk Watermain Improvements Project
City Project No. WA2010-01

NOTES/COMMENTS:

To the attention of all bidders for the above project:

Please find the enclosed Addendum for the above referenced project.

The enclosed ADDENDUM is to be considered as much a part of the Contract Documents as if it were included in the body of the plans and specifications, and will be incorporated in and made a part of the contract when awarded and when formally executed.

The Bidder shall acknowledge in writing, on the bid form, this addendum in order to have the bid considered.

Luis Ponce, P.E.



ADDENDUM NO. 5
To the Contract Documents for:
City of Ferndale, Washington
Thornton To Newkirk Watermain Improvements Project

City of Ferndale Project No. WA2010-01

Item 1

The date of opening bids has been revised to:

June 18, 2025, 3:00 p.m.

All references to the previous bid opening date shall be replaced with the revised bid opening date.

Item 2

16 In. HDPE, DR 9, with IPS sizing per Table 3 of ANSI/AWWA C906, with an average Outside Diameter of 16 In. and an average Inside Diameter of 12.231 In. is an acceptable substitute for the HDPE DIPS pipe specified in Addendum 4. If 16 In. HDPE, DR 9 with IPS sizing is used as the substitute, it shall be measured and paid under Bid Item 22 HDPE PIPE FOR WATERMAIN 14 IN. DIAM.

22 In. HDPE, DR 11, with IPS sizing per Table 3 of ANSI/AWWA C906, with an average Outside Diameter of 22 In. and an average Inside Diameter of 17.76 In. is an acceptable substitute for the HDPE DIPS pipe specified in Addendum 4. If 22 In. HDPE, DR 11 with IPS sizing is used as the substitute, it shall be measured and paid under Bid Item 24 HDPE PIPE FOR CASING 20 IN. DIAM.

Item 3

SPECIFICATIONS

7-09.3(12) General Pipe Installation

Section 7-09.3(12) is supplemented with the following:

The outside diameter beads formed during the butt fusion process of the HDPE DR 9 carrier pipe shall be de-beaded. The inside diameter beads formed during the butt fusion process of the HDPE DR 11 casing pipe shall be de-beaded.

END OF ADDENDUM NO. 5

Acknowledgement that this addendum has been received is required on the Bid Proposal.



Luis Ponce, P.E.